



FieldServer
FS-8700-42 Spectronics
Driver Manual
(Supplement to the FieldServer Instruction Manual)

APPLICABILITY & EFFECTIVITY

Effective for all systems manufactured after November 2015

Kernel Version: 1.01
Document Revision: 0

Contact Information:

Thank you for purchasing the FieldServer.

Please call us for Technical support of the FieldServer product.

Contact Information:

Sierra Monitor Corporation
1991 Tarob Court
Milpitas, CA 95035

Contact number:
+1 408 262-6611
+1 800 727-4377

Email: info@sierramonitor.com

Website: www.sierramonitor.com

TABLE OF CONTENTS

- 1 Spectronics Description 4**
- 2 Driver Scope of Supply 4**
 - 2.1 Supplied by Sierra Monitor Corporation for this driver 4
- 3 Hardware Connections..... 5**
- 4 Data Array Parameters 6**
- 5 Configuring the FieldServer as a Spectronics Client..... 7**
 - 5.1 Client Side Connection Parameters 7
 - 5.2 Client Side Node Parameters 8
 - 5.3 Client Side Map Descriptor Parameters 8
 - 5.3.1 *FieldServer Specific Map Descriptor Parameters* 8
 - 5.3.2 *Driver Related Map Descriptor Parameters* 8
 - 5.3.3 *Timing Parameters* 9
 - 5.4 Map Descriptor Example 10
- 6 Configuring the FieldServer as a Spectronics Server 11**
 - 6.1 Server Side Connection Parameters 11
 - 6.2 Server Side Node Parameters 12
 - 6.3 Server Side Map Descriptor Parameters 12
 - 6.3.1 *FieldServer Specific Map Descriptor Parameters* 12
 - 6.3.2 *Driver Specific Map Descriptor Parameters* 12
 - 6.3.3 *Map Descriptor Example* 13
- Appendix A. Advanced Topics – Spectronics..... 14**
 - Appendix A.1. Default Data Types 14
 - Appendix A.2. Single Writes 14
 - Appendix A.3. Write-Thru Operation 14
 - Appendix A.4. Connection to York Modbus Microgateway 15

LIST OF FIGURES

- Figure 1 - Connection Diagram.....5

1 SPECTRONICS DESCRIPTION

The Spectronics driver allows the FieldServer to transfer data to and from devices over either RS-232 or RS-485 using Spectronics protocol. The FieldServer can emulate either a Server or Client.

The information that follows describes how to expand upon the factory defaults provided in the configuration files included with the FieldServer.

Max Nodes Supported

FieldServer Mode	Nodes	Comments
Client	1	Only 1 client node allowed on Multidrop systems
Server	255	Actual electrical loading may reduce number of usable server nodes

2 DRIVER SCOPE OF SUPPLY

2.1 Supplied by Sierra Monitor Corporation for this driver

Sierra Monitor Corporation PART #	Description
FS-8915-10	UTP cable (7 foot) for RS-232 use
FS-8917-01	RJ45 to DB25M connection adapter

3 HARDWARE CONNECTIONS

The FieldServer is connected to the Spectronics device as shown in connection drawing.

Configure Spectronics device according to manufacturer's instructions




Figure 1 - Connection Diagram

4 DATA ARRAY PARAMETERS

Data Arrays are “protocol neutral” data buffers for storage of data to be passed between protocols. It is necessary to declare the data format of each of the Data Arrays to facilitate correct storage of the relevant data.

Section Title		
Data_Arrays		
Column Title	Function	Legal Values
Data_Array_Name	Provide name for Data Array	Up to 15 alphanumeric characters
Data_Array_Format	Provide data format. Each Data Array can only take on one format.	FLOAT, BIT, UInt16, SInt16, Packed_Bit, Byte, Packed_Byte, Swapped_Byte
Data_Array_Length	Number of Data Objects. Must be larger than the data storage area required by the Map Descriptors for the data being placed in this array.	1-10,000

Example

```
// Data Arrays
Data_Arrays
Data_Array_Name , Data_Array_Format , Data_Array_Length
DA_AI_01 , UInt16 , 200
DA_AO_01 , UInt16 , 200
DA_DI_01 , Bit , 200
DA_DO_01 , Bit , 200
```

5 CONFIGURING THE FIELDSEVER AS A SPECTRONICS CLIENT

For a detailed discussion on FieldServer configuration, please refer to the FieldServer Configuration Manual. The information that follows describes how to expand upon the factory defaults provided in the configuration files included with the FieldServer (See “.csv” sample files provided with the FieldServer).

This section documents and describes the parameters necessary for configuring the FieldServer to communicate with a Spectronics Server.

The configuration file tells the FieldServer about its interfaces, and the routing of data required. In order to enable the FieldServer for Spectronics communications, the driver independent FieldServer buffers need to be declared in the “Data Arrays” section, the destination device addresses need to be declared in the “Client Side Nodes” section, and the data required from the servers needs to be mapped in the “Client Side Map Descriptors” section. Details on how to do this can be found below.

Note that in the tables, * indicates an optional parameter, with the bold legal value being the default.

5.1 Client Side Connection Parameters

Section Title		
Connections		
Column Title	Function	Legal Values
Port	Specify which port the device is connected to the FieldServer	P1-P8, R1-R2 ¹
Protocol	Specify protocol used	Spectronics
Baud*	Specify baud rate	110 – 115200, standard baud rates only
Parity*	Specify parity	None (Vendor limitation)
Data_Bits*	Specify data bits	8 (Vendor limitation)
Stop_Bits*	Specify stop bits	1 (Vendor limitation)
Poll_Delay*	Time between internal polls	0-32000 s, 1 s

Example

```
// Client Side Connections
Connections
Port , Protocol , Baud , Parity , Poll_Delay
P8 , Spectronics , 9600 , None , 0.100s
```

¹ Not all ports shown are necessarily supported by the hardware. Consult the appropriate Instruction manual for details of the ports available on specific hardware.

5.2 Client Side Node Parameters

Section Title		
Nodes		
Column Title	Function	Legal Values
Node_Name	Provide name for Node	Up to 32 alphanumeric characters
Node_ID	Identification number for this Node.	1-255
Protocol	Specify Protocol used	Spectronics
Port	Specify through which port the device is connected to the FieldServer	P1-P8, R1-R2 ²

Example

```
// Client Side Nodes

Nodes
Node_Name      , Node_ID,      , Protocol      , Port
Spec_device1   , 1           , Spectronics   , P8
```

5.3 Client Side Map Descriptor Parameters

5.3.1 FieldServer Specific Map Descriptor Parameters

Column Title	Function	Legal Values
Map_Descriptor_Name	Name of this Map Descriptor	Up to 32 alphanumeric characters
Data_Array_Name	Name of Data Array where data is to be stored in the FieldServer	One of the Data Array names from Section 4.
Data_Array_Offset	Starting location in Data Array	0 to (Data_Array_Length-1) as specified in Section 4.
Function	Function of Client Map Descriptor	Rdbc

5.3.2 Driver Related Map Descriptor Parameters

Column Title	Function	Legal Values
Node_Name	Name of Node to fetch data from	One of the Node names specified in Section 5.2
Length	Length of Map Descriptor	1-125 (Register, AI)
Address	Starting address of read block	40001, 30001, etc
Data_Array_Low_Scale*	Scaling zero in Data Array	-2,147,483,648 to 2,147,483,647, 0
Data_Array_High_Scale*	Scaling max in Data Array	-2,147,483,648 to 2,147,483,647, 100
Node_Low_Scale*	Scaling zero in Connected Node	-2,147,483,648 to 2,147,483,647, 0
Node_High_Scale*	Scaling max in Connected Node	-2,147,483,648 to 2,147,483,647, 100

² Not all ports shown are necessarily supported by the hardware. Consult the appropriate Instruction manual for details of the ports available on specific hardware.

5.3.3 Timing Parameters

Column Title	Function	Legal Values
Scan_Interval	Rate at which data is polled	$\geq 0.001s$

5.4 Map Descriptor Example

```
// Client Side Map Descriptors
```

Map_Descriptors							
Map_Descriptor_Name	Data_Array_Name	Data_Array_Offset	Function	Node_Name	Address	Length	Scan_Interval
CMD_AI_01,	DA_AI_01	, 0	, RDBC	, Spec_Device1	, 30001	, 20	, 1.000s
CMD_AO_01,	DA_AO_01	, 0	, RDBC	, Spec_Device1	, 40001	, 20	, 1.000s
CMD_DI_01,	DA_DI_01	, 0	, RDBC	, Spec_Device1	, 10001	, 20	, 1.000s
CMD_DO_01,	DA_DO_01	, 0	, RDBC	, Spec_Device1	, 00001	, 20	, 1.000s

6 CONFIGURING THE FIELDSEVER AS A SPECTRONICS SERVER

For a detailed discussion on FieldServer configuration, please refer to the FieldServer Configuration Manual. The information that follows describes how to expand upon the factory defaults provided in the configuration files included with the FieldServer (See “.csv” sample files provided with the FieldServer).

This section documents and describes the parameters necessary for configuring the FieldServer to communicate with a Spectronics Client.

The configuration file tells the FieldServer about its interfaces, and the routing of data required. In order to enable the FieldServer for Spectronics communications, the driver independent FieldServer buffers need to be declared in the “Data Arrays” section, the FieldServer virtual node(s) needs to be declared in the “Server Side Nodes” section, and the data to be provided to the clients needs to be mapped in the “Server Side Map Descriptors” section. Details on how to do this can be found below.

Note that in the tables, * indicates an optional parameter, with the bold legal value being the default.

6.1 Server Side Connection Parameters

Section Title		
Connections		
Column Title	Function	Legal Values
Port	Specify which port the device is connected to the FieldServer	P1-P8, R1-R2 ³
Protocol	Specify protocol used	Spectronics
Baud*	Specify baud rate	110 – 115200, standard baud rates only, 9600
Parity*	Specify parity	Even, Odd, None , Mark, Space
Data_Bits*	Specify data bits	7, 8
Stop_Bits*	Specify stop bits	1 (Vendor limitation)
Server_Hold_Timeout*	Specifies time FieldServer will reserve the Server side connection while waiting for the Client side to update data in the Data_Array	>1.0s, 5s

Example

```

// Server Side Connections

Connections
Port , Protocol , Baud , Parity
P1 , Spectronics , 9600 , None
```

³ Not all ports shown are necessarily supported by the hardware. Consult the appropriate Instruction manual for details of the ports available on specific hardware.

6.2 Server Side Node Parameters

Section Title		
Nodes		
Column Title	Function	Legal Values
Node_Name	Name of the Node being represented.	Up to 32 alphanumeric characters
Node_ID		1-255
Protocol	Specify Protocol used	Spectronics
Server_Hold_Timeout*	Specifies time the FieldServer will reserve the Server side connection while waiting for the Client side to update data in Data_Array	>1.0s, 5s

Example

```
// Server Side Nodes

Nodes
Node_Name , Node_ID , Protocol
Spec_Srv_11 , 11 , Spectronics
```

6.3 Server Side Map Descriptor Parameters

6.3.1 FieldServer Specific Map Descriptor Parameters

Column Title	Function	Legal Values
Map_Descriptor_Name	Name of this Map Descriptor	Up to 32 alphanumeric characters
Data_Array_Name	Name of Data Array where data is to be stored in the FieldServer	One of the Data Array names from Section 4
Data_Array_Offset	Starting location in Data Array	0 to (Data_Array_Length-1) as specified in Section 4
Function	Function of Server Map Descriptor	Server
Server_Hold_Timeout*	Specifies time FieldServer will reserve Server side connection while waiting for the Client side to update data in Data_Array	>1.0s, 5s

6.3.2 Driver Specific Map Descriptor Parameters

Column Title	Function	Legal Values
Node_Name	Name of Node to fetch data from	One of the Node Names specified in Section 6.2
Data_Type	Data type	Register, Coil, AI, DI
Length	Length of Map Descriptor	1 - 125
Address	Starting address of read block	40001, 30001, etc
Data_Array_Low_Scale*	Scaling zero in Data Array	-32767 to 32767, 0
Data_Array_High_Scale*	Scaling max in Data Array	-32767 to 32767, 100
Node_Low_Scale*	Scaling zero in Connected Node	-32767 to 32767, 0
Node_High_Scale*	Scaling max in Connected Node	-32767 to 32767, 100

6.3.3 Map Descriptor Example

```
// Server Side Map Descriptors

Map_Descriptors
Map_Descriptor_Name , Data_Array_Name , Data_Array_Offset , Function , Node_name , Address , Length , Data_Array_Low_Scale , Data_Array_High_Scale , Node_Low_Scale , Node_High_Scale
SMD_AI_01          , DA_AI_01          , 0              , Server , Spec_Srv_11 , 30001 , 200 , 0              , 100              , 0              , 10000
SMD_AO_01          , DA_AO_01          , 0              , Server , Spec_Srv_11 , 40001 , 200 , 0              , 100              , 0              , 10000

Map_Descriptors
Map_Descriptor_Name , Data_Array_Name , Data_Array_Offset , Function , Node_name , Address , Length
SMD_DI_01          , DA_DI_01          , 0              , Server , Spec_Srv_11 , 10001 , 200
SMD_DO_01          , DA_DO_01          , 0              , Server , Spec_Srv_11 , 00001 , 200
```

Appendix A. ADVANCED TOPICS – SPECTRONICS

Appendix A.1. Default Data Types

When a Spectronics address range is specified, a particular Data Type is implied. The defaults are as follows:

Address range	Data_Type	Function Code (Write)	Function Code (Read)
40001 - 49999	Register	16	3
30001 - 39999	Analog_Input	n/a.	4
10001 - 19999	Digital_Input	n/a.	2
00001 - 09999	Coil	15	1

Appendix A.2. Single Writes

When writing the default data types can be overwritten using the “Single_Coil” and “Single_Register” settings as part of the Map Descriptor configuration. In that case the Function codes for writes will be as follows:

Address range	Data_Type	Function Code (Write)
40001 - 49999	Single_Register	6
30001 - 39999	Coil	5.

Example: FC 6 = Write Single Register

Add a parameter to the Spectronics client side Map Descriptor called Data_Type.

If you specify the Data_Type as Single_Register and the Function as WRBC or WRBX, then a Spectronics poll with FC 6 will be generated.

Of course Single_Register implies a length of one, and even if you try to set the length longer in the csv file, the length is limited to 1 in the driver.

Appendix A.3. Write-Thru Operation

Consider a client Map Descriptor that is configured to read data using a FC 3 (Read Multiple Register) operation. It is now possible do a write thru operation on the existing Client Map Descriptor by storing data to the Client Map Descriptors Data Array.

The Write Cache Map Descriptor that is created will use the following function codes depending on the Cache Map Descriptor Length and the Clients Node Type.

Single Register Write - FC 6 - When the length of the Cache Map Descriptor is one. This will normally be the case.

Multiple Register Write – FC 16 - When the length of the Cache Map Descriptor is larger than one or the Node_Type has been set to “Block_Mode”.

Appendix A.4. Connection to York Modbus Microgateway

If connecting the FieldServer to a York Modbus Microgateway, the Node_ID of the Microgateway is defined by the address DIP switches. If switch 4 is set to 'On' and the other switches are set to 'off' then Node_ID of the Microgateway is '247', the parity is 'Even', and the stop bits are 1. Other Node_ID combinations can be found in the York Modbus Microgateway Installation Manual.