

Peter Chipkin

From: Alex Fontaine
Sent: Wednesday, October 09, 2013 11:51 AM
To: Peter Chipkin
Subject: RE: VR info

Hello Peter,

Art from Veeder Root has confirmed that the 330020-424 TCP/IP Communications module will work for our CAS 2700-03 Veeder TCP Gateway.

Alex

-----Original Message-----

From: Peter Chipkin [<mailto:pchipkin@chipkin.com>]
Sent: Wednesday, October 09, 2013 11:36 AM
To: Alex Fontaine
Subject: FW: VR info

Look at scan 017 at communication modules. Is that what we need ?

Peter

-----Original Message-----

From: Lisa Richmann [<mailto:lrichmann@superiorequipmentco.com>]
Sent: Wednesday, October 09, 2013 11:24 AM
To: peter@chipkin.com
Subject: VR info

Peter,

Thank you for your time on the telephone today. Attached is the Veeder Root equipment that was ordered for the Job I am referring too.

They are wanting to tie this system into their building control system. I believe it is Johnson controls.

Thank you for your time and help.

Sincerely,

Lisa M. Richmann
Account Manager

Superior Equipment Company
7525-A Sussex Avenue
St. Louis, Missouri 63143

Direct: 314-768-4037
Fax: 314-644-1851